

# A5 - Sample Footing Detail

## TYPICAL TYPE V RESIDENTIAL CONSTRUCTION CRC 2013

THIS DRAWING DEPICTS MINIMUM CODE REQUIREMENTS PER CRC 2013. INFORMATION IS FOR REFERENCE ONLY AND IS NOT A SUBSTITUTE FOR ACCURATE DRAWINGS PREPARED FOR EACH PROPOSED CONSTRUCTION PROJECT.

**WALL CONSTRUCTION:** 2X STUDS @ 16" O.C.  
W/ 3/8" MIN. PLYWD. NAILED W/ 8D OR 10D @ 6"  
O.C. AT ALL EDGES, AND 12" O.C. FIELD.  
BLOCK ALL EDGES.

**VENTING:** PROVIDE UNDERFLOOR VENTING.  
SEE SHEET A3.

**FOUNDATION PLATE:** CRC R317  
2X MIN. PRESSURE  
TREATED WOOD W/ 1/2" OR 5/8" DIA. A.B. W/ 3 X 3  
X 1/4" SQ. WASHER @ 4' OR 6' O.C. MAX. WITHIN  
4" TO 12" FROM END OF PLATE & (2) MIN.

**REINFORCING:** CRC R403.1.3  
#4 REBAR CENTERED IN STEM 3"  
FROM TOP & BOTTOM. WHERE STEM  
EXCEEDS 24" PROVIDE VERTICAL &  
HORIZONTAL REINFORCING AT 18" O.C. PLUS  
#4 VERTS. @ 18" O.C. RECOMMENDED.

FINISH GRADE

UNDISTURBED GRADE

12" MIN. - 24" MIN. IF CLAY  
(OR PER SOILS REPORT)

6" OR 8"  
MIN.

8" CLR. TO  
NON-P.T. WOOD  
OR SHTG.

6" CLR.  
TO SIDING

12" or 18" min

**UNDERFLOOR DRAINAGE:** CRC R405  
PROVIDE UNDERFLOOR DRAINAGE WHERE  
UNDERFLOOR GRADE IS BELOW ADJACENT  
EXTERIOR GRADE.

**STEM WALL:** PROVIDE 7 1/2" MIN. THICK REINF. STEM  
WALL. (6" MAY BE ALLOWED IF ENGINEERED)

**GIRDER SUPPORT:** CRC R502.9 PROVIDE 4X MIN.  
POST W/ SHEET METAL POST CAP & BASE TO P.T.  
PLATE. SPLICE GIRDERS CENTERED DIRECTLY OVER  
POSTS WITH SHT. MTL. SPLICE TYPE POST CAP.

12" MIN. OR P.T.  
18" MIN. OR P.T.

**SPREAD FOOTING:** 16" X 16" MIN. CONCRETE  
PAD. FOOTING SPACING SHALL NOT EXCEED  
6' O.C.. JOIST SPAN NOT TO EXCEED 12'.

**MODIFIED CRC TABLE R403.1 FOOTINGS SUPPORTING WALLS OF LIGHT-FRAME CONSTRUCTION (a) (b) (c) (d) (e)**

NUMBER OF FLOORS SUPPORTED BY FOUNDATION (e)	WIDTH OF FOOTING	THICKNESS OF FOOTING	DEPTH BELOW UNDISTURBED GROUND SURFACE
1	12"	6"	12" OR PER SOILS ENGR.
2	15"	6"	12" OR PER SOILS ENGR.
3	23"	8"	12" OR PER SOILS ENGR.

0 3" 6" 1'  
SCALE: 1" = 1'-0"

Provide consistent Title Block on all  
sheets. Leave margin on all sides.

This scale is for example only. Use 3/4" or 1" or 1 1/2" = 1'-0".  
Typical min. sheet size is 11" x 17"

NAME, ADDRESS AND PHONE NO. OF DESIGNER  
XXX XXX XXX XXX  
XXX XXX XXX XXX

WET SIGNATURE OF DESIGNER ON EACH SHEET  
(AND PROFESSIONAL STAMP IF APPLICABLE)

**EXAMPLE  
RESIDENCE**

**FOOTING DET.**

SAMPLE DRAWING

SCALE: 1" = 1'-0"  
DATE:

SHEET NO.

**A5**